Acoustical treatment 095000-1

## 1.01 CEILINGS

- A. Spline ceilings are NOT acceptable. Use lay-in acoustical ceilings.
- B. All plenum returns need to be provided with baffles.
- C. All restrooms and wet areas to have vinyl faced 2x2 tiled ceilings.

## 1.02 SOUND ATTENUATION

- A. Where suspended acoustical ceilings are used as the termination of walls or for wall anchorage, sound seals below and sound dampening construction above the suspended ceiling shall be used to limit sound transmission from room to room. The entire assemblage shall provide a STC rating of at least 40 or better for walls and ceiling.
- B. Air borne sound shall be reduced or minimized by use of sound absorptive surfaces, seals, offset doors, and careful layout and construction of ductwork and grilles.
- C. Use Formaldehyde-free Thermal and Acoustical Fiber Glass Insulation that is mold and mildew resistant. John Manville Kraft-Faced MR Insulation or equal.

## 1.03 NOISE LEVELS

- A. Noise levels in rooms of different occupancies shall conform to levels recommended by the U.S. National Bureau of Standards.
- B. Noise levels of Mechanical Rooms shall not exceed 75 dB.
- C. Noise levels for fume hoods at full velocity shall not exceed 70 dB.

**Note:** All products used on Edison State College projects must be in compliance with the most current applicable edition of the Florida Building Code.

Acoustical treatment 095000-2

Compon-	Manufactures	Description	Finish
ent		1700 Fi G 1 0 40 0 40 5 /00	D 1 1 1 1 1
Ceiling	Armstrong	1732, Fine fissured, 24"x 24"x 5/8", Angled Tegular	Painted white
		Charlotte Campus only - 1728 or 1728A	
		#607, Ceramaguard, Fine fissured, 24"x	Plastic finish
		24"x 5/8", Tegular for restrooms or wet	
		areas.	
Ceiling Grid	Armstrong	Standard 15/16, Intermediate Duty, Prelude XL	Painted White
Interior		<i>Lee Campus</i> – Walls & Door Frames,	SW 1031-
Wall Finish		Knock Down Finish – Level 3	Modern Gray,
			Satin
		Lee Campus – Doors	SW 1029-
			Neutrino, Satin
		Collier Campus — Walls & Door	
		Frames, Knock Down Finish – Level 3	SW 1109-Ivory, Satin
			outin
		Collier County – Doors	SW 1127-Khaki
			shade, Semi Gloss
		Charlotte Campus - Walls & Door,	SW6112-Biscuit
		Knock Down Finish – Level 3	Satin
		Charlotte Campus - Doors	Natural Finish
Exterior	Premium grade	Lee Campus (New) - Accent & Exterior	SW7038, Tony
Wall	Primer and	doors	Taupe
Finish	Paint,	Lee Campus (New) – Walls, Soffit &	SW7036,
	Satin or Semi Gloss finish	Fascia.	Accessible Beige
		Collier Campus (New) – Field	SW match
			existing color
		Collier Campus (New) - Accent &	SW match
		Exterior doors	existing color
		Charlotte Campus –Exterior doors	Non-painted
			brush aluminum
		Lee Campus (existing only) – Walls,	8674M, Muddy
		Accent & Exterior doors	River

**Note:** All products used on Edison State College projects must be in compliance with the most current applicable edition of the Florida Building Code.

Acoustical treatment 095000-3

		Lee Campus (existing only) -Walls &	8672, Tequilla,
		Soffit & Fascia	
Flooring	Interface	Carpet tile	6395 -
	Cubic		Construction,
			6383-Balance,
			6389-Supports,
			4294-Surface
	Armstrong	Vinyl Tile	51839 Fortress
	Excelon		White & 51804
			Earthstone
			Greige
	Tandus-Centiva	Venue Collection 18"x18"	VS7242
			Hearthstone
	Forbo	Linoleum sheet	
	Crossville	American Classics – Restroom floors	A675
			Stonehenge, 8x8
	Daltile	Semi Gloss – Wall and Base	0135 Almond
	Burke Mercer	Rubbermyte 4" Cove Base	523 Black
			Brown (Lee)
			104 Fudge
			(Charlotte)
	Roppe	700 Series / Vinyl base	193 Black
			Brown (Lee)
	Atlas Concorde	Porcelain Tile - 18 X 18	Carmel
			Travertini
	Bonsal	Grout: Dakota Prairie Polymer #21	
Window frame	Archkote	Powder coating	Bronze 8033
Window Sill	Travertini	Marble	Tan/Beige
Vertical		Fabric Blinds – Offices	Ivory color
Blinds		Vinyl Blinds – Classrooms	

**Note:** All products used on Edison State College projects must be in compliance with the most current applicable edition of the Florida Building Code.